



Certificate of compliance

Applicant: KACO new energy GmbH
Carl-Zeiss-Str. 1
74172 Neckarsulm
Germany

Product: Photovoltaic (PV) inverter

Model: blueplanet 15.0 TL3 M2 WM OD IIG0
blueplanet 20.0 TL3 M2 WM OD IIG0

Use in accordance with regulations:

Automatic disconnection device with three -phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2008 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards :

IEC 61727:2004
Photovoltaic (PV) systems – Characteristics of the utility interface

IEC 62116:2008 / IEC 62116:2014
Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 10TH0306-IEC61727_1

Certificate number: U17-0348

Date of issue: 2017-07-28



Certification body

Holger Schaffer



Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065